

# Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	1912.5 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	69.2V x 70.1H
	At 50% of Imax	41.3V x 41.7H
	At 90% of Imax	16.3V x 16.4H

Beam Flux	Total	1070.6 lumens per klm.
	To 10% of Imax	920.2 lumens per klm.
	To 50% of Imax	560.8 lumens per klm.
	To 90% of Imax	100.2 lumens per klm.

Upward LOR	0.0 %
Downward LOR	107.1 %


Luminaire Efficiency (Light Output Ratio)	106.9 %
---	---------

C Range: 0 - 360DEG  
C Interval: 10.0DEG  
Test Speed: HIGH  
Temperature: 25.3°C  
Operators:  
Test Date: 06 October 2022

γ Range: 0 - 90DEG  
γ Interval: 2.5DEG  
Test System: EVERFINE GO-2000A\_V1 SYSTEM V2.00.456  
Humidity: 65.0%  
Test Distance: 6.265m [K=1.0000]  
Remarks:

## LUMINAIRE PHOTOMETRIC TEST REPORT

NAME: 96GRF3/33012	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F52 x 82	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:



DATA OF LAMP				PHOTOMETRIC DATA	
MODEL	96GRF3/33012			Imax (cd)	382.5
NOMINAL POWER (W)	3			AVAILABILITY (%)	91.7
RATED VOLTAGE (V)	12			Avai. FLUX (lm)	183.3
NOMINAL FLUX (lm)	200			LOR (%)	106.9
LAMPS INSIDE	1			TOTAL FLUX (lm)	213.8
TEST VOLTAGE (V)	12			θ @50% (H,V)	42,41DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm		Φ t	Φ a
	0.00	0.00	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.01	0.01	0.00	0.00	0.00	0.23	0.00
90	0.00	0.01	0.01	0.03	0.04	0.06	0.07	0.08	0.08	0.08	0.07	0.06	0.05	0.04	0.02	0.01	0.00	0.00	0.71	0.00
80	0.00	0.01	0.02	0.05	0.07	0.10	0.12	0.14	0.14	0.14	0.13	0.11	0.09	0.07	0.04	0.02	0.01	0.00	1.27	0.00
70	0.00	0.01	0.03	0.07	0.10	0.14	0.17	0.19	0.20	0.20	0.19	0.16	0.13	0.09	0.06	0.03	0.01	0.00	1.81	0.00
60	0.00	0.01	0.03	0.07	0.10	0.14	0.17	0.19	0.20	0.20	0.19	0.16	0.13	0.09	0.06	0.03	0.01	0.00	1.81	0.00
50	0.00	0.02	0.04	0.08	0.13	0.18	0.22	0.26	0.29	0.29	0.25	0.21	0.17	0.12	0.08	0.04	0.01	0.00	2.40	0.00
40	0.00	0.02	0.05	0.10	0.15	0.22	0.38	0.79	1.12	1.06	0.65	0.33	0.20	0.14	0.09	0.05	0.02	0.00	5.37	1.73
30	0.00	0.02	0.06	0.11	0.17	0.36	1.26	2.77	3.93	3.75	2.41	0.99	0.30	0.16	0.10	0.05	0.02	0.00	16.5	14.3
20	0.00	0.02	0.06	0.12	0.20	0.74	2.75	5.58	7.62	7.55	5.20	2.27	0.57	0.18	0.11	0.06	0.02	0.00	33.1	31.4
10	0.00	0.02	0.06	0.12	0.22	1.10	3.88	7.62	10.4	10.3	7.16	3.32	0.85	0.19	0.11	0.06	0.02	0.00	45.5	44.0
0	0.00	0.02	0.06	0.12	0.23	1.09	3.85	7.65	10.5	10.4	7.13	3.34	0.86	0.19	0.11	0.06	0.02	0.00	45.7	44.2
-10	0.00	0.02	0.06	0.12	0.20	0.74	2.68	5.65	7.75	7.51	5.15	2.32	0.58	0.18	0.11	0.06	0.02	0.00	33.1	31.5
-20	0.00	0.02	0.06	0.11	0.17	0.36	1.22	2.70	3.89	3.77	2.46	1.02	0.29	0.16	0.10	0.05	0.02	0.00	16.4	14.3
-30	0.00	0.02	0.05	0.10	0.15	0.22	0.38	0.77	1.12	1.08	0.67	0.32	0.20	0.14	0.09	0.05	0.02	0.00	5.38	1.81
-40	0.00	0.02	0.04	0.08	0.13	0.17	0.22	0.26	0.29	0.28	0.25	0.21	0.16	0.12	0.08	0.04	0.01	0.00	2.36	0.00
-50	0.00	0.01	0.03	0.07	0.10	0.14	0.17	0.19	0.20	0.20	0.19	0.16	0.13	0.09	0.06	0.03	0.01	0.00	1.78	0.00
-60	0.00	0.01	0.02	0.05	0.07	0.10	0.12	0.13	0.14	0.14	0.13	0.11	0.09	0.06	0.04	0.02	0.01	0.00	1.25	0.00
-70	0.00	0.01	0.01	0.03	0.04	0.05	0.07	0.08	0.08	0.08	0.07	0.06	0.05	0.04	0.02	0.01	0.00	0.00	0.70	0.00
-80	0.00	0.00	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.01	0.01	0.00	0.00	0.00	0.23	0.00
-90	0.00	0.00	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.01	0.01	0.00	0.00	0.00	0.23	0.00
HORIZONTAL (DEG)																				
Φ t	0.04	0.26	0.72	1.36	2.21	5.79	17.6	34.9	47.8	46.9	32.2	15.0	4.77	2.00	1.24	0.64	0.22	0.03	214	---
Φ a	0.00	0.00	0.00	0.00	0.00	2.27	15.0	32.5	45.5	44.6	29.8	12.4	1.29	0.00	0.00	0.00	0.00	0.00	---	183

one-half-peak spread: U:20.8,D:20.8 , L:21.9,R:20.1


NEMA Beam Type: Type 5 x 4 (H x V)

C Range: 0 - 360DEG  
C Interval: 10.0DEG  
Test Speed: HIGH  
Temperature:25.3°C  
Operators:  
Test Date:06 October 2022

γ Range: 0 - 90DEG  
γ Interval: 2.5DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.00.456  
Humidity:65.0%  
Test Distance:6.265m [K=1.0000]  
Remarks:

# ISOCANDELA DIAGRAM

NAME: 96GRF3/33012	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F52 x 82	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:




C Range: 0 - 360DEG  
 C Interval: 10.0DEG  
 Test Speed: HIGH  
 Temperature:25.3°C  
 Operators:  
 Test Date:06 October 2022

γ Range: 0 - 90DEG  
 γ Interval: 2.5DEG  
 Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.00.456  
 Humidity:65.0%  
 Test Distance:6.265m [K=1.0000]  
 Remarks:

## ISOLUX DIAGRAM


NAME: 96GRF3/33012	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F52 x 82	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:



C Range: 0 - 360DEG  
C Interval: 10.0DEG  
Test Speed: HIGH  
Temperature: 25.3°C  
Operators:  
Test Date: 06 October 2022

γ Range: 0 - 90DEG  
γ Interval: 2.5DEG  
Test System: EVERFINE GO-2000A\_V1 SYSTEM V2.00.456  
Humidity: 65.0%  
Test Distance: 6.265m [K=1.0000]  
Remarks:

# Planar Illuminance Curve




C Range: 0 - 360DEG  
 C Interval: 10.0DEG  
 Test Speed: HIGH  
 Temperature: 25.3°C  
 Operators:  
 Test Date: 06 October 2022

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 2.5DEG  
 Test System: EVERFINE GO-2000A\_V1 SYSTEM V2.00.456  
 Humidity: 65.0%  
 Test Distance: 6.265m [K=1.0000]  
 Remarks:

**AAI Figure**

NAME: 96GRF3/33012	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F52 x 82	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:



**Note:** The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG  
 C Interval: 10.0DEG  
 Test Speed: HIGH  
 Temperature: 25.3°C  
 Operators:  
 Test Date: 06 October 2022

γ Range: 0 - 90DEG  
 γ Interval: 2.5DEG  
 Test System: EVERFINE GO-2000A\_V1 SYSTEM V2.00.456  
 Humidity: 65.0%  
 Test Distance: 6.265m [K=1.0000]  
 Remarks:

## LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRF3/33012	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F52 x 82	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:

Table--1

UNIT: cd

H (DEG) V (DEG)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-90	0.28	0.28	0.28	0.28	0.28	0.27	0.27	0.23	0.19	0.16	0.13	0.20	0.27	0.26	0.24	0.24	0.25	0.24	0.23
-85	0.28	0.31	0.33	0.37	0.41	0.43	0.44	0.50	0.56	0.60	0.63	0.67	0.70	0.71	0.71	0.73	0.73	0.73	0.71
-80	0.28	0.34	0.39	0.47	0.60	0.70	0.80	0.94	1.07	1.18	1.28	1.38	1.47	1.54	1.59	1.63	1.65	1.66	1.65
-75	0.28	0.37	0.45	0.64	0.83	1.05	1.26	1.49	1.70	1.89	2.05	2.20	2.32	2.43	2.51	2.57	2.61	2.63	2.62
-70	0.28	0.39	0.57	0.82	1.13	1.44	1.77	2.06	2.33	2.59	2.83	3.04	3.22	3.38	3.50	3.59	3.64	3.68	3.68
-65	0.28	0.42	0.69	1.04	1.45	1.86	2.24	2.63	2.98	3.32	3.63	3.90	4.12	4.30	4.47	4.59	4.66	4.70	4.70
-60	0.28	0.45	0.80	1.26	1.77	2.24	2.73	3.19	3.63	4.03	4.39	4.72	5.00	5.23	5.41	5.53	5.62	5.67	5.68
-55	0.28	0.50	0.94	1.49	2.07	2.64	3.20	3.75	4.24	4.71	5.14	5.51	5.82	6.09	6.30	6.45	6.55	6.60	6.60
-50	0.28	0.55	1.07	1.71	2.35	3.01	3.66	4.26	4.83	5.36	5.83	6.27	6.65	6.95	7.21	7.42	7.57	7.64	7.64
-45	0.28	0.60	1.19	1.91	2.63	3.37	4.08	4.75	5.39	5.96	6.51	7.01	7.45	7.87	8.27	8.61	8.86	8.99	9.01
-40	0.28	0.64	1.31	2.09	2.89	3.70	4.46	5.20	5.88	6.54	7.16	7.76	8.39	9.08	9.87	10.9	12.7	13.5	13.6
-35	0.28	0.68	1.42	2.26	3.13	4.01	4.82	5.60	6.35	7.07	7.79	8.59	9.63	11.7	16.6	24.1	31.0	35.0	35.9
-30	0.28	0.71	1.52	2.41	3.35	4.26	5.13	5.95	6.77	7.57	8.49	9.72	13.3	23.2	36.7	51.1	64.1	72.0	74.6
-25	0.28	0.74	1.61	2.55	3.53	4.48	5.40	6.27	7.14	8.05	9.28	12.2	23.8	42.0	65.7	89.7	113	128	133
-20	0.28	0.77	1.68	2.67	3.69	4.67	5.62	6.53	7.46	8.54	10.3	18.4	38.6	67.4	103	142	175	195	200
-15	0.28	0.79	1.74	2.76	3.82	4.81	5.78	6.74	7.75	8.98	11.9	27.3	54.7	94.9	146	195	234	260	267
-10	0.28	0.80	1.78	2.83	3.91	4.92	5.90	6.89	7.96	9.35	15.0	35.7	70.4	120	183	236	283	319	328
-5	0.28	0.81	1.81	2.87	3.96	4.98	5.97	6.98	8.07	9.56	16.9	41.3	80.4	140	205	263	316	355	370
0	0.28	0.81	1.82	2.89	3.98	5.00	6.00	7.01	8.10	9.61	17.5	43.2	84.8	148	214	276	330	368	382
5	0.28	0.81	1.81	2.87	3.97	4.99	5.97	6.97	8.06	9.51	16.5	40.9	83.2	141	204	263	315	352	364
10	0.28	0.80	1.78	2.83	3.92	4.93	5.90	6.88	7.93	9.26	14.5	35.5	71.9	124	181	232	277	311	326
15	0.28	0.79	1.74	2.77	3.83	4.83	5.78	6.73	7.72	8.92	11.7	27.2	56.1	99.2	148	193	229	255	264
20	0.28	0.77	1.68	2.68	3.71	4.68	5.61	6.51	7.43	8.51	10.2	18.2	39.1	70.2	106	144	175	194	199
25	0.28	0.75	1.61	2.56	3.56	4.50	5.41	6.24	7.10	8.02	9.21	12.1	24.3	43.5	67.8	93.3	115	131	133
30	0.28	0.72	1.53	2.42	3.37	4.29	5.15	5.93	6.72	7.52	8.45	9.66	13.6	23.4	37.4	52.3	64.8	72.3	73.4
35	0.28	0.69	1.43	2.27	3.16	4.05	4.85	5.61	6.31	7.02	7.77	8.60	9.62	11.9	16.9	24.2	30.9	34.6	35.4
40	0.28	0.65	1.32	2.10	2.93	3.75	4.50	5.23	5.88	6.51	7.14	7.77	8.42	9.12	10.1	11.3	13.2	14.2	14.1
45	0.28	0.61	1.20	1.92	2.66	3.41	4.14	4.80	5.42	5.98	6.52	7.03	7.52	7.95	8.35	8.72	9.06	9.23	9.20
50	0.28	0.56	1.08	1.72	2.36	3.05	3.71	4.32	4.90	5.44	5.91	6.35	6.73	7.05	7.30	7.51	7.64	7.72	7.74
55	0.28	0.51	0.95	1.50	2.07	2.66	3.24	3.81	4.33	4.81	5.25	5.64	5.96	6.23	6.43	6.57	6.65	6.69	6.69
60	0.28	0.46	0.82	1.27	1.77	2.25	2.75	3.24	3.70	4.13	4.50	4.85	5.13	5.37	5.53	5.65	5.72	5.75	5.74
65	0.28	0.43	0.71	1.05	1.45	1.85	2.24	2.64	3.03	3.38	3.71	4.00	4.24	4.43	4.58	4.69	4.75	4.78	4.77
70	0.28	0.41	0.60	0.83	1.13	1.44	1.75	2.05	2.33	2.61	2.87	3.09	3.29	3.45	3.58	3.67	3.72	3.74	3.73
75	0.28	0.38	0.48	0.65	0.82	1.05	1.26	1.47	1.68	1.87	2.04	2.19	2.33	2.45	2.54	2.61	2.65	2.66	2.65
80	0.28	0.35	0.42	0.47	0.58	0.69	0.80	0.93	1.04	1.16	1.26	1.36	1.44	1.52	1.58	1.62	1.64	1.65	1.65
85	0.28	0.32	0.35	0.37	0.39	0.43	0.46	0.50	0.53	0.58	0.63	0.65	0.66	0.69	0.72	0.72	0.71	0.72	0.72
90	0.28	0.28	0.29	0.28	0.28	0.28	0.28	0.28	0.27	0.28	0.28	0.27	0.26	0.26	0.26	0.26	0.25	0.25	0.24

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:06 October 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.00.456

Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks:

## LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRF3/33012	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F52 x 82	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:

Table--2

UNIT: cd

H (DEG) V (DEG)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-90	0.23	0.23	0.22	0.20	0.20	0.21	0.12	0.03	0.08	0.14	0.16	0.18	0.19	0.19	0.19	0.18	0.18	0.19	
-85	0.71	0.70	0.67	0.64	0.63	0.61	0.57	0.52	0.49	0.46	0.41	0.35	0.33	0.31	0.27	0.24	0.21	0.19	
-80	1.63	1.60	1.55	1.49	1.42	1.33	1.23	1.11	1.00	0.89	0.77	0.64	0.56	0.47	0.37	0.29	0.24	0.19	
-75	2.59	2.54	2.47	2.38	2.27	2.14	2.00	1.84	1.67	1.48	1.27	1.05	0.86	0.66	0.51	0.35	0.27	0.19	
-70	3.64	3.57	3.48	3.35	3.19	3.01	2.80	2.56	2.32	2.06	1.80	1.52	1.22	0.93	0.66	0.45	0.30	0.19	
-65	4.66	4.58	4.47	4.31	4.11	3.89	3.63	3.34	3.01	2.66	2.31	1.95	1.61	1.22	0.86	0.55	0.33	0.19	
-60	5.63	5.54	5.41	5.22	4.99	4.74	4.43	4.06	3.69	3.28	2.84	2.40	1.95	1.52	1.05	0.64	0.36	0.19	
-55	6.56	6.47	6.33	6.13	5.87	5.55	5.17	4.77	4.33	3.86	3.37	2.83	2.30	1.79	1.26	0.76	0.40	0.19	
-50	7.58	7.44	7.24	6.98	6.68	6.32	5.91	5.44	4.93	4.41	3.85	3.26	2.65	2.04	1.46	0.87	0.44	0.19	
-45	8.86	8.64	8.32	7.92	7.48	7.05	6.58	6.07	5.50	4.91	4.30	3.66	2.97	2.30	1.65	0.98	0.48	0.19	
-40	12.8	11.7	10.2	9.22	8.48	7.83	7.23	6.64	6.04	5.39	4.72	4.01	3.29	2.54	1.81	1.09	0.51	0.19	
-35	32.9	27.7	19.7	13.3	10.2	8.78	7.90	7.19	6.51	5.84	5.10	4.35	3.57	2.75	1.96	1.19	0.54	0.19	
-30	69.6	60.0	45.4	30.7	17.5	10.8	8.73	7.74	6.95	6.23	5.46	4.65	3.81	2.94	2.10	1.28	0.57	0.19	
-25	124	106	82.4	57.6	34.7	17.9	10.2	8.34	7.35	6.55	5.77	4.90	4.01	3.11	2.22	1.36	0.60	0.19	
-20	189	164	129	90.7	57.6	30.9	13.7	9.03	7.72	6.84	6.02	5.12	4.20	3.26	2.32	1.43	0.61	0.19	
-15	252	220	177	129	82.4	45.5	20.0	9.92	8.08	7.08	6.21	5.30	4.35	3.38	2.40	1.48	0.63	0.19	
-10	309	270	216	161	104	58.8	27.6	11.4	8.39	7.26	6.35	5.44	4.46	3.46	2.45	1.52	0.64	0.19	
-5	354	308	244	183	121	68.3	32.3	12.3	8.60	7.38	6.44	5.52	4.53	3.51	2.49	1.54	0.65	0.19	
0	368	325	256	191	125	70.4	33.3	12.6	8.69	7.43	6.48	5.56	4.55	3.53	2.50	1.55	0.65	0.19	
5	349	308	246	183	119	67.0	31.5	12.4	8.62	7.39	6.45	5.53	4.53	3.52	2.49	1.54	0.65	0.19	
10	312	271	219	162	104	58.0	27.0	11.5	8.43	7.27	6.36	5.45	4.47	3.47	2.46	1.52	0.64	0.19	
15	253	222	180	128	80.3	44.5	20.0	10.2	8.17	7.10	6.22	5.32	4.37	3.39	2.40	1.49	0.63	0.19	
20	190	165	129	89.3	55.7	30.4	13.9	9.30	7.83	6.88	6.04	5.15	4.22	3.27	2.32	1.43	0.62	0.19	
25	124	104	79.9	54.7	33.8	18.0	10.5	8.51	7.46	6.61	5.80	4.94	4.04	3.13	2.23	1.37	0.60	0.19	
30	68.8	57.0	43.3	29.2	17.7	11.3	8.98	7.89	7.06	6.30	5.51	4.70	3.84	2.96	2.11	1.29	0.58	0.19	
35	32.9	27.0	19.5	13.6	10.6	9.07	8.09	7.33	6.63	5.93	5.17	4.40	3.60	2.77	1.97	1.20	0.55	0.19	
40	13.4	12.0	10.4	9.51	8.71	8.00	7.38	6.78	6.17	5.49	4.79	4.06	3.32	2.56	1.82	1.09	0.52	0.19	
45	9.05	8.80	8.44	8.07	7.63	7.18	6.70	6.21	5.62	5.00	4.37	3.70	3.01	2.32	1.66	0.99	0.49	0.19	
50	7.68	7.54	7.34	7.08	6.77	6.42	6.02	5.55	5.03	4.48	3.90	3.30	2.68	2.06	1.47	0.88	0.45	0.19	
55	6.65	6.55	6.40	6.21	5.95	5.64	5.27	4.86	4.40	3.92	3.41	2.87	2.34	1.80	1.27	0.77	0.41	0.19	
60	5.70	5.62	5.48	5.30	5.08	4.81	4.49	4.13	3.75	3.33	2.88	2.43	1.98	1.53	1.05	0.65	0.37	0.19	
65	4.73	4.65	4.52	4.36	4.17	3.94	3.69	3.38	3.06	2.71	2.35	1.99	1.61	1.22	0.86	0.56	0.34	0.19	
70	3.69	3.62	3.52	3.40	3.24	3.05	2.84	2.61	2.36	2.10	1.82	1.53	1.22	0.93	0.66	0.47	0.31	0.19	
75	2.63	2.58	2.51	2.41	2.30	2.17	2.03	1.87	1.68	1.49	1.27	1.05	0.86	0.65	0.51	0.38	0.28	0.19	
80	1.63	1.60	1.55	1.49	1.41	1.32	1.22	1.11	1.00	0.88	0.77	0.65	0.55	0.45	0.37	0.32	0.25	0.19	
85	0.71	0.69	0.67	0.65	0.61	0.58	0.55	0.53	0.48	0.43	0.40	0.37	0.33	0.29	0.28	0.25	0.22	0.19	
90	0.24	0.23	0.23	0.22	0.21	0.20	0.20	0.20	0.20	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:06 October 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.00.456

Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks: